


DG Sets (3 Nos. 650KVA) Clarifications from pre-Bid Meeting on 05/02/2010

- The plan /drawing of the DG sets installation site & electrical works as per the tender Document is attached
- Since the supply and installation of DG sets will take place in a phased manner over a period of 8-10 months, CCMB shall be open to discussing mutually acceptable payment terms with the successful bidder. Requests for unsecured advance or mobilization advance will however not be entertained. CCMB is entitled to avail the benefit of excise duty exemption under notification No.51/96 dated 23.7.1996. Bidders may explore the possibility of extending this benefit by proposing an invoicing arrangement directly from manufacturer to the Director CCMB for the supply part of DG sets

Please see attached drawing



- P -1 DG -1 INCOMER PANEL
- P -2 DG -2 INCOMER PANEL
- P -3 DG -3 INCOMER PANEL
- P -4 OUTGOING PANEL OF DG 1,2 &3
- P -5,6 SYNCHRONISATION PANEL
- P -7 750 KVA PANEL

LAY-OUT OF D.G SETS ROOM